

From: [Redacted]
To: [Redacted]
Cc: [Redacted]
Subject: Carpathia drive
Date: 07 April 2022 13:47:04
Attachments: [image001.png](#)
[image002.jpg](#)
[image003.jpg](#)
[image004.jpg](#)
[image005.jpg](#)
[image006.jpg](#)

[Redacted]
It was good to see you this morning. Further to our meeting can you please confirm/action the following:

Confirmation of intumescent collars in concrete slab between basement/ground floor and first floor where piping runs through the slab;

Labelling of dry riser inlets on the site in order that crews can easily identify which dry riser inlet services each block;

Confirmation as to whether or not the residents will carry out a Waking Watch during the interim period between the Waking Watch currently in place and the installation of the fire alarm system that will allow for Temporary Simultaneous Evacuation;

Confirmation that you have received funding from the Waking Watch relief fund that will allow you to implement the installation of a fire alarm system;

The date of commencement for the installation of the Alarm System.

[Redacted] [Redacted] [Redacted] [Redacted] During this time can you please contact either [Redacted] if you have any questions.

Regards,



[Redacted]
[Redacted]
High Risk Residential Building Inspection Program
[Redacted]

[Redacted]



Headquarters
Leigh Road, Eastleigh
Hampshire, SO50 9SJ
02380644000