



Hampshire & IOW Fire and Rescue Service

Community Safety Department

Note For File No: 10729128		
Inspector: [REDACTED]	Signed:	Date: 07/04/22

Site visit with [REDACTED] and [REDACTED] further to case meeting on 5th April '22. See attached Contemporaneous notes for information gathered from walk around of site. Met [REDACTED] (Trinity Estates) on site. [REDACTED] confirmed that all compartmentation works within the FRA have been carried out. Remedial works to all fire doors will commence in September '22. These works are to adjust and fix minor issues.

Email sent to [REDACTED] (see attached) asking for further confirmation/information on intumescent collars, installation of AFD, waking watch plan, labelling of dry riser inlets.



Attached Image.msg Carpathia drive.msg

[REDACTED]

It was good to see you this morning. Further to our meeting can you please confirm/action the following:

Confirmation of intumescent collars in concrete slab between basement/ground floor and first floor where piping runs through the slab;

Labelling of dry riser inlets on the site in order that crews can easily identify which dry riser inlet services each block;

Confirmation as to whether or not the residents will carry out a Waking Watch during the interim period between the Waking Watch currently in place and the installation of the fire alarm system that will allow for Temporary Simultaneous Evacuation;

Confirmation that you have received funding from the Waking Watch relief fund that will allow you to implement the installation of a fire alarm system;

The date of commencement for the installation of the Alarm System.

[REDACTED]. During this time can you please contact either [REDACTED] if you have any questions.

Regards,



