



Hampshire & IOW Fire and Rescue Service

Community Safety Department

Note For File No: 10729128		
Inspector: [REDACTED]	Signed:	Date: 12/10/21

Update from [REDACTED] on regularity of emergency lighting, AOV and dry riser testing. This is now being carried out monthly and dry riser every 6 months.



Fw_ Hants Fire &
Rescue Visit to 286.m: