

**Hampshire & IOW Fire and Rescue Service**

**Community Safety Department**

<b>Note For File No: 10729128</b>		
<b>Inspector:</b> [REDACTED]	<b>Signed:</b>	<b>Date: 03/11/21</b>

Email from [REDACTED] with update on fire safety matters.

Hi [REDACTED]

Please see attached update of all notice boards changed to covered ones, numbers on all floor levels, fire boxes have had locks changed and accessible and fire questionnaire responses are being put in them this week. Simultaneous evacuation plans have been put up also.

Please note that the waking watch company now in place are Triton

[Waking Watch | Waking Watch Security | Triton Security \(triton-security.com\)](#)

The office is still based in the GF void room in block 29-36 Carpathia Drive

An alarm company are attending this week to quote for an alarm system.

Fire stopping started last week and the fire door survey will be received this week.

Kind regards

[REDACTED]  
[REDACTED]



The Deanery -  
Southampton.msg

15/11/21

Further updates from [REDACTED] with info on updated fire notices and FRAs. Also specification for upgrade to Fire Alarm system to allow for temporary simultaneous evacuation and removal of waking watch. Re-iteration to [REDACTED] that this is their risk and they must check with their own risk assessor that the specifications are satisfactory for what is required.



Updated fire notices  
.msg



286 - The Deanery  
.msg



RE\_286 - The  
Deanery .msg