



HAMPSHIRE  
FIRE AND  
RESCUE  
SERVICE

FM/6/10/5  
(07/08)

**Hampshire Fire And Rescue Service**

**Community Safety Department**

<b>Note For File No: 10443765</b>		<b>Job Number: 2792614</b>
<b>Inspector:</b> [REDACTED]	<b>Signed:</b> [REDACTED]	<b>Date:03/03/2021</b>



triage letter single  
premises EVERELL C

-- This email has originated from outside HIWFRS. Take extra care when opening links or attachments! Report any suspicious emails to [Spam@hantsfire.gov.uk](mailto:Spam@hantsfire.gov.uk) --

Hi [REDACTED] I have visited the property now. The H+S appears good to me, Portsmouth City Council and Hants Fire gave the building a full investigation in 2018 after Grenfell so I would expect it to be ok. It is solid concrete, there is a communal area of three flats on the top floor which is protected by a fire door, the adjacent lift lobby is protected from the escape stairwell and bin chute by fire doors, and there is window in the exit with louvres that are permanently open. There is a serviced riser too. I have taken photos of these for your information (see below). If I can be of any further assistance please let me know.

Kind regards,

[REDACTED]









